

October 31, 2018

SUBJECT: FAP Route 805 (IL 161) Project STP-PGGY(853) Section 7BR, 7BR-1 Clinton County Contract No. 76887 Item No. 58, November 9, 2018 Letting Addendum B

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

- 1. Revised the Table of Contents to the Special Provisions
- 2. Added page 152 to the Special Provisions

Prime contractors must utilize the enclosed material when preparing their bid and must include any changes to the Schedule of Prices in their bid.

Very truly yours,

Jack A. Elston, P.E. Bureau Chief Bureau of Design and Environment

Jutte abuchly RE.

By: Ted B. Walschleger, P. E. Engineer of Project Management

cc: Jeffrey Keirn, Region 5, District 8; D. Carl Puzey; Tim Kell

CWR/cr

FAP Route 805 (IL 161) Project STP-PGGY(853) Section 7BR, 7BR-1 Clinton County Contract No. 76887

DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION (BDE)	77
DISPOSAL FEES (BDE)	
EQUIPMENT PARKING AND STORAGE (BDE)	89
FUEL COST ADJUSTMENT (BDE)	90
GROOVING FOR RECESSED PAVEMENT MARKINGS (BDE)	92
MIX ASPHALT – LONGITUDINAL JOINT SEALANT (BDE)	94
HOT-MIX ASPHALT – OSCILLATORY ROLLER (BDE)	99
HOT MIX ASPHALT – QUALITY CONTROL FOR PERFORMANCE (BDE)	100
HOT-MIX ASPHALT – TACK COAT (BDE)	106
LIGHTS ON BARRICADES (BDE)	106
MATERIAL TRANSFER DEVICE (BDE)	107
PAYMENTS TO SUBCONTRACTORS (BDE)	108
PORTABLE CHANGEABLE MESSAGE SIGNS (BDE)	108
PORTLAND CEMENT CONCRETE (BDE)	109
PORTLAND CEMENT CONCRETE BRIDGE DECK CURING (BDE)	
PROGRESS PAYMENTS (BDE)	111
RECLAIMED ASPHALT PAVEMENT AND RECLAIMED ASPHALT SHINGLES (BDE)	112
STEEL COST ADJUSTMENT (BDE)	120
SUBCONTRACTOR AND DBE PAYMENT REPORTING (BDE)	123
SUBCONTRACTOR MOBILIZATION PAYMENTS (BDE)	124
TRAINING SPECIAL PROVISIONS (BDE)	124
IDOT TRAINING PROGRAM GRADUATE ON-THE-JOB TRAINING SPECIAL PROVISIO	ON 127
TEMPORARY PAVEMENT MARKING (BDE)	129
TRAFFIC BARRIER TERMINAL, TYPE 1 SPECIAL (BDE)	131
WARM MIX ASPHALT (BDE)	132
WEEKLY DBE TRUCKING REPORTS (BDE)	133
SWPPP	134
404 PERMIT	142
ROCKFILL - REPLACEMENT	152

ROCKFILL - REPLACEMENT

(Revised October 30, 2018)

This work consists of the placement of rockfill beneath cast-in-place and precast concrete box culverts. This work shall be done as shown on the plans or as directed by the Engineer.

Materials shall meet the requirements of the following Articles of the Standard Specifications:

Item	Article	
CA-07	1004.04ª	
Rockfill	1005.01	

^a Except coarse aggregate quality shall be as directed by the Engineer.

The gradation of rockfill shall be selected based on the following table:

Rockfill Layer Thickness	Rockfill Gradation	Minimum Cap Thickness
Less than 1 ft	Gradations with a maximum size of 4 inches approved by the Engineer. ^b	4 inches
Greater than 1 ft	Primary Crusher Run	6 inches
Greater than 3 ft	Primary Crusher Run or Shot Rock ^c	6 inches

^b Gradations with a maximum size of 2 inches or smaller shall have less than 6% passing the No. 200 sieve. ^c Shot rock dimensions shall not exceed 18 inches.

Rockfill shall be placed following the excavation of the unsuitable soil. No compaction of rockfill is required. For cast-in-place concrete box culverts, rockfill shall be capped with CA-07. For precast concrete box culverts, the rockfill shall be capped with the porous granular bedding according to Article 540.06 of the Standard Specifications.

This work shall be measured and paid for at the contract unit price per cubic yard for ROCKFILL - REPLACEMENT. For precast concrete box culverts, porous granular bedding material and the excavation required for bedding shall be paid for according to Article 540.08 of the Standard Specifications.