

Rubblization Pavement and Subsurface Investigation

FAI 57

Contract 78380

Southbound

Station	Location				Thickness, in.			Subbase condition			Subgrade IBV					Soil Information						
	PS	PL	DL	DS	AC Overlay	PCC	Subbase	Sound	SI Deter	Deter	0-6"	6-12"	12-18"	18-24"	24-30"	Classification	Sand	Silt	Clay	LL	PI	% H <sub>2</sub> O
83+00					4 1/2	12					4.0	10.0	16.0	17.0								
" "					7 1/2		6		AGG		7.0	7.0	10.0	14.0								
93+00					3 1/2	10 1/4	4		AGG		4.0	7.0	14.0	17.0								
" "					7 1/4		8		AGG		4.0	7.0	17.0	17.0								
102+00					4	10	6		AGG		16.0	14.0	17.0	20.0								
" "					11		6		AGG		14.0	14.0	14.0	17.0								
113+00					4 1/4	10 1/4	6		AGG		8.5	10.0	12.0	14.0								
" "					7 1/2		6		AGG		5.5	5.5	10.0	10.0								
123+00					4	10	6		AGG		7.0	8.5	10.0	10.0								
" "					9		6		AGG		7.0	7.0	14.0	17.0								
132+00					3 1/2	10 1/2	6		AGG		7.0	7.0	12.0	17.0								
" "					7 1/2		6		AGG		4.0	7.0	17.0	20.0								
142+00					4 1/2	10 1/4	6		AGG		5.5	7.0	14.0	17.0								
" "					8		8		AGG		18.0	23.0	30.0	30.0								
152+00					4	10 1/2	4		AGG		4.0	4.0	5.5	7.0								
" "					7 1/2		8		AGG		7.0	10.0	17.0	20.0								
162+00					4 1/4	10 1/2	6		AGG		8.5	5.5	17.0	17.0		CL A-6(9)	30	48	22	33.3	13.7	15
" "					7 1/2		6		AGG		5.5	14.0	21.0	30.0								
172+00					4 1/2	10 1/4	4		AGG		14.0	18.0	20.0	20.0								
" "					8 1/2		8		AGG		16.0	8.5	8.5	8.5								
182+00					5	10 3/4	6		AGG		10.0	14.0	7.0	17.0								
" "					8		6		AGG		10.0	14.0	17.0	17.0								