STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths						
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4		
3, 4	1'-5"	1'-11''	2'-1''	2'-4"		
5	1'-9''	2'-5"	2'-7"	2'-11''		
6	2'-1''	2'-11''	3'-1''	3'-6''		
7	2'-9''	3'-10''	4'-2"	4'-8''		
8	3′-8′′	5′-1′′	5′-5′′	6′-2′′		
9	4'-7''	6'-5''	6′-10′′	7′-9′′		

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + 1^{l_2} " + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length




BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =


DESIGNED	-	JLS	
CHECKED	-	KWS	
DRAWN	_	VH	
CHECKED	_	MRB	
BSD-1			 11-1-09


STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION



INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt. "B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms. (E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi vield strenath.

All reinforcement shall be lapped and tied to the splicer bars. Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers. See approved list of bar splicer assemblies and mechanical splicers for alternatives.

> BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO. 099-3298

TOTAL SHEET NO. F.A.U. RTE. SECTION COUNTY SHEET NO. S34 57 04-00090-07-BR WILL 42 S47 SHEETS CONTRACT NO. 63442 FED. ROAD DIST. NO. | ILLINOIS | FED. AID PROJECT

benesch

Engineers · Surveyors · Planners
205 North Michigan Avenue, Suite 2400
Chicago, Illinois 60601