

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths					
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4	
3, 4	1'-5"	1'-11''	2'-1"	2'-4"	
5	1'-9''	2'-5"	2'-7"	2'-11''	
6	2'-1"	2'-11''	3'-1"	3'-6''	
7	2'-9"	3'-10''	4'-2"	4'-8"	
8	3'-8"	5'-1"	5′-5″	6'-2"	
9	4'-7"	6'-5"	6'-10''	7'-9"	

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + $1_2'''$ + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar		Table for minimum lap length		
	size	required			
West Abutment	#6	8	3		
West Abutment	#6	2	3		
East Abutment	#6	8	3		
East Abutment	#6	2	3		

Bridge Deck Reinforcement Threaded Threaded splicer bar (E) Threaded splicer


BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

6'-0"

No. required =

		٦
DESIGNED	IJL.	FEBRUARY 11, 2010
CHECKED	GGE	EXAMINED & Carl Prayey
DRAWN	baliva	PASSED Ralph E. andersa
CHECKED	IJL GGE	ENGINEER OF BRIDGES AND STRUCTURES
BSD-1		11-1-09


STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION




INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required
WWW.PAshaliki		

NOTES

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS FARMINGTON ROAD OVER FAI 474 SN 072-0118

	SHEET NO. 6	F.A.I. RTE.	A.I. SECTION		COUNTY	TOTAL SHEETS	SHEET NO.	
		474	11 R	S-3		PEORIA	40	26
	6 SHEETS				CONTRACT	NO. 68	502	
		FED. RC	AD DIST. NO.	ILLINOIS F	ED. AI	D PROJECT		