


CABLE OR DUCT MARKER DETAIL

DETAIL NOT TO SCALE




L-823 CONNECTION DETAIL

- CONTRACTOR SHALL PROVIDE CABLE IDENTIFICATION MARKERS ATTACHED TO BOTH SIDES OF EACH CABLE CONNECTION. CABLE IDENTIFICATION MARKERS SHALL BE 3M SCOTCH HEAT-BONDING #SCS-HB21 OR EQUIVALENT.
- ENTIRE CONNECTOR SHALL BE ENCASED IN HEAT SHRINK TUBING HAVING INTEGRAL GLUE SEALANT AT ENDS ONLY.

TYPICAL SPLICE AND CONNECTOR DETAIL





NOTE:
2" FRANGIBLE COUPLING, FLOOR FLANGE, AND STAINLESS STEEL ANCHOR BOLTS SHALL BE PROVIDED AS REQUIRED.



no. date by ckd description 0 04/25/08 BJQ MAR ISSUED FOR BID





date	detailed
02/13/08	L. TUCKER
designed	checked
B. QUINLAN	A. RAHMAN

RUNWAY 9/27 LIGHTING, NAVAIDS AND SIGNAGE; RUNWAY 18/36 WIND CONES AND

ELECTRICAL DETAILS 7 project E207 sheet 21 file 47463E207.dwg