



## ELECTRICAL SERVICE - PANEL DIAGRAM (TYPICAL FOR POLE AND GROUND MOUNTED SERVICE) SERVICE INSTALLATION POLE MOUNT (SHOWN)




HANDHOLE COVER

ANTI-CORROSION COMPOUND SHALL BE APPLIED ON ALL BOLT/ CONNECTION ASSEMBLIES. -STAINLESS STEEL NUT AND 2 STAINLESS STEEL WASHERS

CAST CORNER FRAME WEB-UL LISTED GROUND -COMPRESSION CONNECTOR DETAIL "A"



DETAIL "B"



## HANDHOLE COVER & FRAME - GROUNDING DETAIL

(NOT TO SCALE)

(2) 1/2"  $\times$  1 1/4" STAINLESS STEEL BOLT WITH SPLIT LOCK WASHER AND NYLON INSERT LOCKOUT WELDED TO  $\overline{\phantom{M}}$ FRAME AND TO COVER, (TYPICAL) ∠EXISTING HANDHOLE GROUNDING CABLE FRAME AND COVER (PAID FOR SEPARATELY)

**EXISTING HANDHOLE COVER & FRAME - GROUNDING DETAIL** 

(NOT TO SCALE)


NOTES:


## SECTION 337 20 WRS-6 LAKE 318 218 FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT CONTRACT NO. 62030


COUNTY

GROUNDING SYSTEM

- 1. THE GROUNDING SYSTEM SHALL CONSIST OF AN INSULATED CONDUCTOR TYPE XLP, NO. 6 A.W.G., STRANDED COPPER TO BE INSTALLED IN RACEWAYS. THE GROUNDING CABLE SHALL BE INSTALLED IN A CONTINUOUS MANNER AS SHOWN ON THE CABLE PLAN PROVIDED. ALL GROUNDING CONDUCTORS SHALL BE BONDED TO METAL ENCLOSURE (HANDHOLE, POST, MAST ARM, CONTROLLER, ETC.). GROUND ROD SHALL BE  $3/4^{\prime\prime\prime}$  DIA.  $\times$  10'-0" (20mm  $\times$  3.0m) LONG, COPPER CLAD. ONE GROUND ROD SHALL BE INSTALLED AT ALL POST FOUNDATIONS, POLE FOUNDATIONS, CONTROLLER CABINET FOUNDATION AND ELECTRICAL SERVICE INSTALLATION AS INDICATED ON THE CABLE PLAN. IF THERE ARE ANY SPECIAL CONDITIONS SUCH AS SUB-SURFACE CONDITIONS OR INSTALLATION PROBLEMS, THE RESIDENT ENGINEER SHALL BE NOTIFIED OR CONTACT THE BUREAU OF TRAFFIC, ILLINOIS DEPARTMENT OF TRANSPORTATION DISTRICT ONE AT
- 2. THE NEUTRAL CONDUCTOR AND THE GROUND CONDUCTOR SHALL BE CONNECTED IN THE SERVICE INSTALLATION. AT NO OTHER POINT IN THE TRAFFIC SIGNAL SYSTEM SHALL THE NEUTRAL AND GROUND CONDUCTORS BE CONNECTED.
- 3. ALL EQUIPMENT GROUNDING CONDUCTORS SHALL TERMINATE AT THE GROUND BUS
- 4. THE CONTRACTOR SHALL PROVIDE A GROUND CABLE WITH CONNECTORS BETWEEN THE HANDHOLE COVER AND HANDHOLE FRAME.







3/4" (20mm) HEAVY-DUTY GROUND ROD CLAMP (BURNDY TYPE GRC OR APPROVED EUAL)

- ALL CLAMPS SHALL BE BRONZE OR COPPER, UL APPROVED.
  GROUND CABLE SHALL BE LOOPED OVER HOOKS IN THE HANDHOLES 6.5' (2.0m) SLACK SHALL BE PROVIDED IN SINGLE HANDHOLES 13' (4.0m) OF SLACK SHALL BE PROVIDED IN DOUBLE HANDHOLES. 5' (1.4m) OF SLACK SHALL BE PROVIDED BETWEEN FRAME AND COVER.
- ACCESS COVER-GROUNDING ELECTRODE CONDUCTOR 1/C #6 GROUND (GREEN COLOR CODED) GROUND LUG (BURNDY TYPE KC, K2C,-OR APPROVED EQUAL) HEAVY DUTY GROUND ROD CLAMP, EXOTHERMIC WELD, OR U.L. APPROVED CONNECTOR. EQUIPMENT GROUNDING 1/C #6 GROUND (GREEN COLOR CODED) (TYPICAL FOR ALL GROUND RODS) -3/4" × 10' (20mm × 3.0m) COPPER CLAD GROUND ROD MAST ARM POLE / POST-GROUNDING DETAIL

ILLINOIS DEPARTMENT OF TRANSPORTATION DISTRICT 1 STANDARD TRAFFIC SIGNAL DESIGN DETAILS

SCALE: VERT. NONE HORIZ. DATE 1-01-02

\*DATE-TIME\* \*DGN-SPEC\*