For anchor rod size and placement, see Support Frame Detail Sheet.

12-#9 v4(E) bars-

3 hoops minimum

DESIGNED

CHECKED

OS4-F4

\* Anchor rod shall be ground or filed to bright metal at clamp and cable connection location.

## STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

3" • Galvanized Steel
Conduit. Thread


and cap both ends.

3'-6".

Elevation (Bottom)

END VIEW

Elevation (Top)



Contract #

## BAR LIST - EACH FOUNDATION

Bar	Number	Size	Length	Shape	
V4(E)	24	#9	F less 5"		

## NOTES:

The foundation dimensions shown are based on the presence of mostly cohesive soils with an average Unconfined Compressive Strength (Qu) of at least 1.25 tsf, which must be determined by previous soil investigations at the jobsite. When other conditions are indicated, the boring data will be included in the plans and the foundation dimensions shown will be the result of site specific designs.

If the conditions encountered are different than those indicated, the Contractor shall notify the Engineer to determine if the foundation dimensions need to be modified. If dimensions "B" or "F" are revised by more than 12" by the Contractor, "as-built" plans shall be prepared and submitted to the District Bureau of Operations for future reference.

No sonotubes or decomposable forms shall be used below the lower conduit entrance. Permanent metal forms or other shielding may not be left in place below that elevation without the Engineer's written permission.

Concrete shall be placed monolithically, without construction joints.

Backfill shall be placed per Article 502 of Standard Specification and prior to erection of support column.

A normal surface finish followed by a Bridge Seat Sealer application will be required on concrete surfaces above the lowest elevation 6" below finished ground line. Cost included in Drilled Shaft Concrete Foundation.

3'-0" \$\phi\$ Co.

#9 v4(E)

SECTION A-A

9" 9" 9" 9" 9" 9" 9" 9"

SIDE ELEVATION

9'-0" & to &

Approved clamps
for grounding\*

#6 copper wire or cable

34" \$\psi x 10'-0" copper weld ground rod driven into ground 9'-0". Cost of rod, cable, conduit, caps and clamps shall be included in Drilled Shaft Concrete Foundations.

Structure Station Number		Station Elevation Top	Left Foundation			Right Foundation				Class SI		
	Station		Elevation Bottom	Α	В	F	Elevation Top	Elevation Bottom	А	В	F	Concrete (Cu. Yds.)
6S084I055R86.9	234+00.00						598.00	577.90	2'-1"	18'-0"	20′-1"	10.62
6S084I055L107.0	202+54.00						591.50	571.17	2'-4"	18'-0"	20'-4"	10.60
				***************************************								
				***************************************					~~~~			
											***************************************	

<u>PLAN</u>

EXAMINED

PARRED

1-7-05

NUMBER REVISION DATE

3'-0" ¢

DETAILS FOR 12" • SUPPORT FRAME

TYPE III-A TRUSS

OVERHEAD SIGN STRUCTURES
DRILLED SHAFT DETAILS

F.A.I. 55 (I-55) SECTION D-6 ITS #1 SANGAMON COUNTY