
GENERAL NOTES


- I. FACE OF LIGHT POLES TO BE INSTALLED 24" FROM FACE OF CURB.
- 2. DURING INSTALLATION OF ALL UNDERGROUND ELECTRICAL, EXERCISE EXTREME CAUTION DUE TO UNDERGROUND POWER AND UTILITY LINES THAT MAY BE EXISTING.

KEYED NOTES

- VERIFY EXISTING CONDITION AND MATCH.
- 2 AFTER INSTALLATION OF NEW CONDUIT(S), BACKFILL TRENCH(ES) MITH CRUSHED STONE BACKFILL.




POLE & BASE DETAIL




TRENCH DETAIL


BY NOT TO SCALE




POLE & BASE DETAIL #2




5 CONTROL DETAIL
E3 NOT TO SCALE



B POLE & BASE DETAIL #3





SHEET 14 OF 14

E3