

AC SURGE PROTECTOR/TVSS, SUITABLE FOR 120/240 VAC, 1 PH, 3W PLUS GROUND SYSTEM WITH SURGE CURRENT RATING OF 240 KA, 8 x 20 MICROSECOND WAVE PER MODE & STATUS INDICATION LIGHTS IN A NEMA 12 ENCLOSURE, LIGHTNING PROTECTION CORP. MODEL LPC 2020-8U-G, OR APPROVED EQUAL. AC SURGE PROTECTOR/TVSS DEVICE SHALL BE INSTALLED ON THE LEFT HAND SIDE OF THE PANELBOARD. MAINTAIN LEADS AS SHORT & AS STRAIGHT AS POSSIBLE FROM THE PANELBOARD TO THE AC SURGE PROTECTOR/TVSS DEVICE. PROVIDE DUCT SEAL AT CONDUIT TERMINATIONS.

1 #10 THWN, 1 #10 NEUTRAL, 1 #10 GND IN LOW VOLTAGE WIREWAY & CONDUIT. PROVIDE LTFMC AT FINAL CONNECTION TO TRANSFORMER.

HIGH VOLTAGE & LOW VOLTAGE CIRCUITS SHALL NOT BE INSTALLED IN THE SAME RACEWAY

FURNISH & INSTALL A WEATHERPROOF WARNING LABEL FOR EACH METER SOCKET, PANELBOARD, LOAD CENTER, DISCONNECT & CONTROL PANEL TO WARN PERSONS OF POTENTIAL ELECTRIC ARC FLASH HAZARDS, PER THE REQUIREMENTS OF NEC 110.16 "FLASH PROTECTION".

NOTES


1. ALL VAULT WORK, AIRFIELD WORK, AND/OR POWER OUTAGES SHALL BE COORDINATED WITH THE AIRPORT MANAGER.
2. ALL ELECTRICAL EQUIPMENT SHALL BE INSTALLED IN CONFORMANCE WITH NFPA 70 (NEC MOST CURRENT ISSUE IN FORCE), THE RESPECTIVE EQUIPMENT MANUFACTURER'S DIRECTIONS AND ALL OTHER APPLICABLE LOCAL CODES, LAWS, ORDINANCES AND REQUIREMENTS IN FORCE. ANY INSTALLATIONS WHICH VOID THE U.L. LISTING, ETL LISTING, (OR OTHER THIRD PARTY LISTING) AND/OR THE MANUFACTURER'S WARRANTY OF A DEVICE SHALL NOT BE PERMITTED.
3. ALL EQUIPMENT SHOWN IS NEW UNLESS NOTED OTHERWISE.
4. COORDINATE ELECTRIC SERVICE WORK WITH THE SERVING ELECTRIC UTILITY COMPANY, RURAL ELECTRIC CONVENIENCE COOPERATIVE
ATTN: MR. MARTY HINTON
P.O. BOX 19
AUBURN, IL 62615-0019
PHONE: 217-438-6197
FAX: 217-438-3212
5. CONTRACTOR SHALL CONFIRM POWER REQUIREMENTS WITH THE ACTUAL NAMEPLATE ON EACH CONSTANT CURRENT REGULATOR AND ADJUST CIRCUIT BREAKER, WIRE SIZES & CONDUIT SIZES TO CONFORM WITH NEC & MANUFACTURER'S RECOMMENDATIONS WHERE APPLICABLE. WIRE SIZES SHOWN ON THE PLANS ARE MINIMUM.
6. SEE PANELBOARD SCHEDULES FOR ADDITIONAL REQUIREMENTS FOR EACH RESPECTIVE PANEL.
7. BRANCH CIRCUITS TO REGULATORS SHALL BE INSTALLED IN THE RESPECTIVE LOW VOLTAGE WIREWAY/DUCT, WITH GRSC AT TRANSITIONS AND UL LISTED LIQUID TIGHT FLEXIBLE METAL CONDUIT AT FINAL CONNECTIONS TO THE REGULATORS. CONDUITS SHALL BE SIZED IN ACCORDANCE WITH NEC.
8. BOND ALL REGULATORS TO THE RESPECTIVE VAULT GROUND BUS WITH A DEDICATED #6 AWG BONDING JUMPER FOR EACH REGULATOR.
9. LTFMC DENOTES LIQUID TIGHT FLEXIBLE METAL CONDUIT UL LISTED, SUNLIGHT RESISTANT, & SUITABLE FOR GROUNDING.

NEW VAULT ELECTRICAL ONE-LINE DIAGRAM

BY	
REVISION	
DATE	

TAYLORVILLE MUNICIPAL AIRPORT
TAYLORVILLE, ILLINOIS
A.I.P. PROJ.: 3-17-0100-87
I.L. PROJ.: TAZ-3166

HEL Project No. 828-035WYGD_0800	
Filename E-606.DWG	
Scale 1"=30'	
Date 04/22/05	
LAYOUT	KNL 02/16/05
DRAWN	MV 02/16/05
REVIEWED	CAH 03/28/05



CONSTRUCT
RUNWAY 9-27
PROPOSED VAULT
ELECTRICAL ONE-LINE
DIAGRAM SHEET 1